

# **Utility Commission of New Smyrna Beach**

## **Water System Analysis Part 2**

### **Water Treatment, Storage and Pumping**

Prepared by  
Quentin L. Hampton Associates,  
Inc.

March 2006

# Water Treatment Process

- The Utility Commission of New Smyrna Beach (UCNSB) aka "U.C." owns and operates a single water treatment plant on Glencoe Road.
- It is a conventional lime softening treatment facility and has a rated capacity of 10.38 MGD.
- Raw water is supplied to the facility from 19 wells in three (3) wellfields, Glencoe, Samsula and Western.

# Well Capacity and Capacity Requirements

	2005 (MGD)	2010 (MGD)	2015 (MGD)	2020 (MGD)	2025 (MGD)
Projected ADF	5	6.49	6.71	7.0	7.12
Existing Well Capacity	10.5	10.5	10.5	10.5	10.5
*Capacity Requirement (ADF x 2.0)	10	12.98	13.42	14.0	14.24
Required Additional Well Capacity		2.48	2.92	3.50	3.74

*\*Allows for Well Rotation*

- **Plans are currently under way to install 5 new wells @ 350 GPM/each.**

# Well Capacity and Capacity Requirements

- Five (5) new wells are currently proposed for construction in the vicinity of the U.C.'s existing wastewater treatment facility.
- The five wells should have an average capacity of 350 GPM/well.
- **Total Capacity = 2.52 MGD**
- In order to achieve production capacity by 2010, construction is needed in FY '07/'08 with design/permitting no later than FY '06/'07.

# Well Capacity and Capacity Requirements

- In addition to groundwater pumping capacity, raw water transmission capacity is a constraint.
- An existing 20" raw water transmission main conveys approximately 60% of the U.C.'s raw water.
- Existing raw water transmission main capacity is adequate through 2020; however, there is no redundancy.
- If the existing transmission main is damaged, or out of service, the U.C. could immediately lose greater than half of its water production capacity!

# Well Capacity and Capacity Requirements

- In order to provide operation redundancy and long term sustainability, the U.C. should pursue the following:

➔ **Additional Finished Water Interconnects.**

➔ **Alternative Water Supplies.**

➔ **A Secondary Raw Water Main.**

# Treatment Processes

## ■ Aeration


- ▶ The aeration structures have sufficient capacity for a 12.4 MGD rating.

## ■ Softening

- ▶ Thus, overall available softening capacity is 12.4 MGD.

## ■ Filtration

- ▶ The filters at the Glencoe Plant have the Capacity of 10.38 MGD.
- ▶ It may be possible to 're-rate' the filters to 12.4 MGD.



\* OUT OF SERVICE, NOT REQUIRED

GLENCOE WTP PROCESS SCHEMATIC

# Treatment Processes

## ■ Disinfection

- ▶ Chlorine solution is fed first, followed by ammonia to form chloramines.
- ▶ The Glencoe Water Treatment Plant is subject to modified 'CT' requirements.
- ▶ The WTP must demonstrate 'CT' compliance by January 1, 2006.
- ▶ Actual CT (370) > Required, CT (321).

**System Does Meet CT Requirements**

# Treatment Processes

## ■ Chlorination Equipment

- ▶ Chlorine gas is fed from one ton cylinders.
- ▶ Average chlorine demand is less than 500 #/day, therefore, adequate capacity exists for disinfection of 12.4 MGD.
- ▶ The chlorine gas feed system is subject to federal risk management guidelines.
- ▶ An element of the plan includes public notification for residents and businesses within close proximity of the plant.

# Treatment Processes

## ■ Chlorination Equipment

▶ As development moves closer to the plant, the U.C. may wish to consider safer disinfection options.


▶ Options which should be evaluated are:

➡ *Option #1*, Bulk Liquid Sodium Hypochlorite (NaOCl).

➡ *Option #2*, On-site NaOCl generation.

➡ *Option #3*, Ozonation.

# STORAGE AND PUMPING



GLENCOE WTP PUMPING SCHEMATIC

# Age and Status of Existing Transfer Pumps

Pump #	Capacity	Approx Age (YRS)
#1	2,000 GPM	30+
#2	Out of Service	N/A
#3	3,500 GPM	30+
#11	2,200 GPM	14
#12	2,200 GPM	14
<b>TOTAL</b>	<b>9,900 GPM (14.26 MGD)</b>	

# Storage and Pumping

## ■ Transfer Pumps (Continued)

- ▶ The useful service life of vertical turbine pumps is 15-20 years.
- ▶ All pumps should be replaced. The pumps should be equipped with variable frequency drives, (VFD's) and new instrumentation.

## ■ Storage

- ▶ The U.C. operates four (4) storage tanks. (1) at Glencoe WTP, (2) at Smith Street and (1) on the South Peninsula.
- ▶ A new 1 MG tank is needed at Third Avenue.

# Storage and Pumping

## ■ High Service Pumping

- ▶ The U.C. operates three (3) high service pump stations. Glencoe WTP, Smith Street and Beachside South.
- ▶ The existing Smith Street pump station is constructed below the 100 year flood plain and is subject to inundation.
- ▶ The existing structure electrical and mechanical equipment is in poor condition.
- ▶ Existing flooded suction centrifugal pumps limit the useful storage capacity of the tanks.
- ▶ The existing structure will not meet current wind load requirements; retrofit of the existing structure would cost more than building new.
- ▶ A new pump station at Smith Street is recommended.

# Emergency Power

- ▶ The emergency power generator at the Glencoe Water Treatment Plant is not equipped with an Automatic Transfer Switch (ATS).
- ▶ At Glencoe WTP, an ATS should be installed in addition to new power distribution equipment.
- ▶ The existing generator is marginally sized to handle all plant loads and simultaneous high service pumping.
- ▶ A separate generator, enclosure, and ATS is proposed for installation at the high service pump station at Glencoe WTP.

# Project Summary Spreadsheet

Item #s	Project Description	Implementation Date	Est. Cost
1	Wellfield Expansion	2008	\$1,625,000
2	Lime Softening Upgrades (lime slaker and softener rehab)	2006/07	\$210,000
3	Rebuild/Replace Softener Drives	2008	\$50,000
4	Rehab. Lime Silo, Electrical & Instrumentation	2010	200,000
5	Filter Upgrades	2008	250,000
6	Glencoe WTP Low Pressure & Transfer Pumping	2006/07	\$793,500
7	Glencoe WTP High Service Pumps	2008	\$75,000
8	Smith Street Pump Station	2006/07	\$1,087,500
*9	3 <sup>rd</sup> Avenue Storage Tank & Pump Station	2006/07	\$1,375,000
10	ATS & Power Distribution @ Glencoe WTP	2006/07	\$100,000
11	Smith Street Generator	2006/07	\$280,000
12	3 <sup>rd</sup> Avenue Generator	2006/07	\$160,000
13	Glencoe H.S. Generator	2008	\$280,000
	*(3 <sup>rd</sup> Avenue Project also listed in Part 1 Study, not included in this total)		
<b>TOTAL</b>	<b>2006/07 Projects</b>		<b>\$2,631,000</b>
<b>TOTAL</b>	<b>2008 Projects</b>		<b>\$2,280,000</b>
<b>TOTAL</b>	<b>2010 Projects</b>		<b>\$200,000</b>

# QUESTIONS

